

AGENDA
GLOUCESTER BOARD OF HEALTH
February 10, 2011 @ 6:15 PM
CATA Training Room (1st floor)
3 Pond Rd
GLOUCESTER, MA 01930

.....

1. Public Oral Communication

2. Minutes from 1/06/11

3. Director's Report

4. New Business:

A. Hoarding Case

B. Illegal Tattoo Operation

C. 33 Fuller St
(Map 168, Lot 15)

Francis T. McCarthy, Owner
Griffin Engineering, Engineer

Request permission to upgrade the existing failed system with the following variances:

1. Reduce the property line setback of the leach field from 10' to 7' [15.211(1)]
2. Reduce the setback of leach field to foundation from 20' to 7.5' w/ barrier [15.211(1)]
3. Reduce the separation of bottom of leach field to ESHGW from 4' to 2' [15.212]

D. 9 Bayle Ln
(Map 257, Lot 16)

David & Angela Ciampa, Owners
Mill River Consulting, Engineer

Request permission to upgrade the existing failing system with the following variances:

1. To reduce setbacks of septic tank, Soil Absorption System & pump chamber to property line from 10' to 3'. [15.405 (1)(a)]
2. To reduce setbacks of septic tank and pump chamber to foundation wall from 10' to 1'. [15.405(1)(b)]
3. To reduce the setback of Soil Absorption system to foundation wall from 20' to 3'. [GOSWR 2.1]

5. Concerns of the Board