

CITY OF GLOUCESTER

Health Department

3 Pond Road, City Hall Annex
Gloucester, Massachusetts 01930

PHONE: 978-325-5260

EMAIL: healthdepartment@gloucester-ma.gov

WEBSITE: www.gloucester-ma.gov



Public Health
Prevent. Promote. Protect.

Agenda

Gloucester Board of Health

Septic Subcommittee

May 31, 2019

8:30 AM

Annex Conference Room

3 Pond Road

Gloucester, MA

CITY CLERK
GLOUCESTER, MA
2019 MAY 29 AM 8:16

The following items will be under review by the Gloucester Board of Health Septic Subcommittee:

30 Lake Road (167/05)


Property owned by Doris Parrish Trust and represented by Daniel Johnson, DSD, Inc.

- 10' required between septic tank and pump chamber from property line (15.211)
 - 3' proposed for septic tank
 - 3' proposed for pump chamber
- 10' required between leaching facility and property line (15.211)
 - 6' proposed to leaching facility
- 10' required between septic tank and pump chamber from foundation (15.211)
 - 1.5' proposed for septic tank
 - 3' proposed for pump chamber
- 10' required between leaching facility and water lines (15.211)
 - 4' proposed between leaching facility and water lines
- Request to reduce the size of the leaching facility by 50% from 550 square feet to 275 square feet.
- Request to reduce offset to groundwater from 4' to 2'
- Request to reduce the depth of naturally occurring pervious soil from 4' to 26"

6 Atlantic Street (242/148)

Property owned by Devin Carr and represented by John Judd, Gateway Consultants, Inc.

- 50' required between leaching facility and a drainage catch basin (15.211)
 - 31' proposed



CITY OF GLOUCESTER

Health Department

3 Pond Road, City Hall Annex
Gloucester, Massachusetts 01930

PHONE: 978-325-5260

EMAIL: healthdepartment@gloucester-ma.gov

WEBSITE: www.gloucester-ma.gov



Public Health
Prevent. Promote. Protect.

33 Two Penny Lane (260/09)

Property owned by Steve DiFillippo and represented by John Judd, Gateway Consultants, Inc.

- *100' required between leaching facility and wetland (G.O.S.W.W.R)*
 - *37' provided*

A Meeting with Brad Robertson of All Seasons Septic to discuss the revocation of the septage haulers license assigned to All Seasons Septic

For more information, please contact Craig LoPiccolo at the Gloucester Health Department
978-325-5263
clopiccolo@gloucester-ma.gov