

**AGENDA**  
**GLOUCESTER BOARD OF HEALTH**  
**September 2, 2010 @ 6:15 PM**  
**CATA Training Room (1<sup>st</sup> floor)**  
**3 Pond Rd**  
**GLOUCESTER, MA 01930**

.....

**1. Public Oral Communication**

**2. Director's Report**

**3. New Business:**

**A. 38 Craft's Rd**

*Dorothy Gibbons, owner*  
*Mill River Consulting, engineer*

Request permission to upgrade the existing failed septic system with the following variances:

1. To reduce setback from the soil absorption system to the property line (10' required, 2' provided) 310 CMR 15.405(1)(a)
2. To reduce the requirement of 2 deep holes per disposal area (2 required, 1 provided in SAS #2) 310 CMR 15.405(1)(k)
3. To reduce 5' overdig requirement (5' required, 2.5' provided) 310 CMR 15.255(5)

**B. 6 Wyoma Rd**

*Robert & Kathryn Wilson, owners*  
*Gateway Consultants, engineer*

Request permission to upgrade the existing failed septic system with the following variances:

1. To situate a leaching facility within 200' of a coastal wetland (25' provided). G.O.S.W.R. #2
2. To situate leaching facility where less than 2' of pervious soil material exists. (10"-20" exists) 310 CMR 15.415(2)
3. To situate a leaching facility within 20' of a foundation. (10' provided) G.O.S.W.R. #2

**C. 26 & 28 Atlantic St.**

*Sandra Arvilla, owner  
Gateway Consultants, engineer*

Request permission to replace the existing failed septic system with a holding tank with the following variance:

1. To situate a tank within 10' of a property line. (4' and 2' provided) 310 CMR 15.405 (1)b

**4. Concerns of Board Members**

**5. Elections**