



Health Department

3 Pond Road, City Hall Annex
Gloucester, Massachusetts 01930

PHONE: 978-325-5260

EMAIL: healthdepartment@gloucester-ma.gov

WEBSITE: www.gloucester-ma.gov



Public Health
Prevent. Promote. Protect.

CITY CLERK
GLOUCESTER, MA
17 MAR 27 AM 10:35

Agenda

Gloucester Board of Health

Septic Subcommittee

March 30, 2017

8:30 AM

Annex Conference Room

3 Pond Road

Gloucester, MA

The following items will be under review by the Gloucester Board of Health Septic Subcommittee:

- **10 Waterside Lane (Map 204, Lot 25)**
Property owned by Robert Wolfe and represented by Peter Ogran, Hayes Engineering.

To discuss a variance to Gloucester's Onsite Wastewater Regulations to allow a leaching facility to be installed within 100 feet of a coastal resource area (91 feet provided); a variance to Title 5 to allow a leaching facility to be installed within 50 feet of a bordering vegetated wetland (26 feet provided); a variance to Gloucester's Onsite Wastewater Regulations to allow a Waterloo Biofilter to be installed within 100 feet of a coastal resource area (91 feet provided) and 100 feet of bordering vegetated wetland (42 feet provided); a local upgrade request to reduce the requirement of two deep holes per disposal area to one (310 CMR 15.405(1)(k)), and a local upgrade request to allow for a sieve analysis in lieu of a percolation test (310 CMR 15.405(1)(i)).



Health Department

3 Pond Road, City Hall Annex
Gloucester, Massachusetts 01930

PHONE: 978-325-5260

EMAIL: healthdepartment@gloucester-ma.gov

WEBSITE: www.gloucester-ma.gov



Public Health
Prevent. Promote. Protect.

- **15 Waterside Lane (Map 201, Lot 110) – Development inquiry**

For more information, please contact Thor Akerley at the Gloucester Health Department.
978-325-5263

takerley@gloucester-ma.gov

This meeting is recorded