

A new perspective on metals and other contaminants in fluoridation chemicals*

Phyllis J. Mullenix

Andover, MA, USA

Background: Fluoride additives contain metal contaminants that must be diluted to meet drinking water regulations. However, each raw additive batch supplied to water facilities does not come labeled with concentrations per contaminant. This omission distorts exposure profiles and the risks associated with accidents and routine use.

Objectives: This study provides an independent determination of the metal content of raw fluoride products.

Methods: Metal concentrations were analyzed in three hydrofluorosilicic acid (HFS) and four sodium fluoride (NaF) samples using inductively coupled plasma-atomic emission spectrometry. Arsenic levels were confirmed using graphite furnace atomic absorption analysis.

Results: Results show that metal content varies with batch, and all HFS samples contained arsenic (4.9–56.0 ppm) or arsenic in addition to lead (10.3 ppm). Two NaF samples contained barium (13.3–18.0 ppm) instead. All HFS (212–415 ppm) and NaF (3312–3630 ppm) additives contained a surprising amount of aluminum.

Conclusions: Such contaminant content creates a regulatory blind spot that jeopardizes any safe use of fluoride additives.

Keywords: Fluoride additives, Metal contaminants, Drinking water regulations

Background

Prior studies have linked human ingestion of heavy metals to agricultural applications of municipal wastes and commercial fertilizers.^{1–3} However, fluoride additives used in the water fluoridation process are another potential source for metal ingestion by humans and have not yet been adequately investigated. The production of fluoride additive involves phosphate rock, which contains cadmium (Cd), arsenic (As), lead (Pb), chromium (Cr), mercury (Hg), nickel (Ni), vanadium (V), uranium (U), and other radionuclides and metals at levels that vary by geographical origin.^{2–4} Metal contaminants in fluoride additives are a potential contamination source of the water supply.

In an attempt to limit hazardous exposures via drinking water, the US Environmental Protection Agency (EPA) requires that quality and safety assurance programs screen the metal content of drinking water after the use of additives like fluorosilicic acid (H_2SiF_6 or hydrofluorosilicic acid [HFS]), sodium fluorosilicate (Na_2SiF_6), and sodium

fluoride (NaF). The EPA recommends that finished drinking water have fluoride at the desired levels of ≤ 1.2 mg/l (less than one-third the EPA Maximum Contaminant Level, MCL), while other contaminants stay at or below levels considered safe ($<$ one-tenth the respective EPA MCL).^{5,6} Silicate has no MCL, but there is a 16 mg/l maximum drinking water level (MDWL) restriction, and radionuclide levels are not to exceed detection limits of EPA Test Method 900.0.^{5–7}

Both the American Water Works Association (AWWA) and the National Sanitation Foundation International (NSF) provide guidelines for the selection and use of fluoride additives. Quality controls consist of multiple standards (i.e., ANSI/NSF Standards 60 and 61, ANSI/AWWA B701–B703) and testing and certification programs.^{5,6,8} When an NSF certified additive is dosed into water according to the specified maximum use level (MUL) (typically 6.0 mg/l for HFS; 2.3 mg/l for NaF; 2.0 mg/l for Na_2SiF_6), the dilution process should limit the doses of metals delivered to the public via fluoridation. However, data from 2000 to 2006 and 2007 to 2011 show that controlled dilution procedures resulted in detectable levels of up to 13 metal contaminants and that in finished drinking water samples 43–50% had detectable As; <1 –2% had Pb; 0–1% had Cd; and

*Presented in part at the North Jersey District Water Supply Commission's Educational Seminar "Pharmaceutical Contaminants in the Water Treatment Industry," Wanaque, New Jersey, July 14, 2009.

Correspondence to: Phyllis J. Mullenix, Post Office Box 753, Andover, MA, USA. Email: pjmttox@gmail.com

<1% had Cr.^{5,6} Controlled dilution is intended to restrict contaminants to concentrations at or below the ANSI/NSF Standard 60 single product allowable concentration (SPAC) limits (0.1 MCL for contaminants except fluoride) and thereby lessen concern for metal exposure originating from fluoridation.

The controlled dilution process does not protect public safety in the case of accidents and therefore it is necessary to shift focus from regulation of diluted fluoride products to raw fluoride additives – which are never contaminant free. In the United States, state and local agencies are responsible for regulating the use of raw fluoride additives and on numerous occasions these authorities have had to deal with mishandling accidents.^{9–22} Such accidents fall into one of three categories: water distribution overfeeds (fluoride levels ≥ 4 or ≥ 7 mg/l in school systems); non-overfeeds (fluoride levels >1.2 mg/l but <4 or <7 mg/l in school systems); and industrial accidents during the handling, transport, or storage of additives at or near water treatment facilities. Regardless of category, fluoride is typically the only contaminant identified or monitored during accidents. Overfeed accidents occur when the MUL is exceeded and excess fluoride additive enters the drinking water. This can result in illnesses in children and adults, attributed to fluoride and not to fluoride combined with other contaminants such as As and Pb.^{23–26} In non-overfeed accidents, the public may not be informed for up to 12 months that their drinking water has fluoride levels >1.2 mg/l as long as the MCL of 4 mg/l is not exceeded. Furthermore, the public is never informed about the concentration levels of the other contaminants also present in the water.

In an industrial accident in Utah where a water facility storage tank ruptured and released 300 gallons of HFS, authorities anticipated the high levels of fluoride (495 ppm) in the nearby waterway, but did not anticipate the coexisting 42.6 ppb arsenic discovered during the follow-up investigation. The manufacturer's material safety data sheet (MSDS) on file for the spilled HFS did not warn of any potential arsenic content.²⁷ This example demonstrates how gaps in regulation allow unreported metal content to become potential health risks during accidental exposure to raw or improperly diluted fluoride additives.

Contaminant content defines exposure and determines health impact. It is well established that batch-to-batch variation in contaminant content can change biological response and that even trace amounts of contaminants can lower the threshold dose for an effect, particularly when there are synergistic interactions and the overall effect is greater than the sum of effects caused by contaminants acting alone.²⁸

Synergism between contaminants fosters an underestimation of risks, like that occurring with combinations of Pb, As, Cd, and Cr or fluoride coexisting with aluminum or beryllium.^{29–35} Combinations of contaminants can also trigger chemical degradation, generating decomposition products with toxicity greater than that of the original compounds. In a previous trace contaminant study of commercially available HFS samples, one in four samples had signs of decomposition where an unexpectedly high level of hydrofluoric acid (3.3%) exceeded the AWWA standard (1%).³⁶

The MSDS's for fluoride additives do not specify threshold limit values for decomposition products such as hydrogen fluoride. While they do warn against combining fluoride with metals to avoid corrosion, they do not describe the risks that decomposition creates for workers as a result of airborne contamination. Although the MSDS's for HFS and NaF additives list a threshold limit value (TLV) of 2.5 mg(F)/m³, they avoid the 0.5 ppm TLV (0.41 mg(F)/m³ at 25°C and 760 Torr) for occupational exposure to hydrogen fluoride.³⁷ This incomplete disclosure can result in unexpected outcomes, like that encountered by manufacturers of fluoroether compounds (i.e. sevoflurane) when trace amounts of metal oxides from metallic or glass surfaces of containers or medical devices initiated chemical degradation to form highly toxic levels of hydrogen fluoride, hydrofluoric acid, and silicon tetrafluoride.^{38–41} Any metal initiated degradation of fluorinated compounds is important to consider, especially since drinking water increasingly contains fluorinated pharmaceuticals.^{42,43} Beryllium oxyfluoride, barium fluoride, or magnesium fluoride are acutely more toxic than compounds such as sodium fluoride, calcium fluoride, or magnesium oxide.^{44–46} Given established hierarchies in potential toxicity, it is important to consider the risks associated with the combination of metals and fluoride in an exposure scenario.

To understand the risks associated with using fluoride additives, it is necessary to first evaluate the metal content of the raw fluoride product before the application of controlled dilution procedures. While NSF programs require annual unannounced inspections of fluoride additive suppliers, inspection results are kept private by nondisclosure agreements to protect business interests. There is no routine screening for discrepancies between inspection results and the manufacturer's Certificate of Analysis or MSDS sent with each additive batch.^{5,6} Description of the metal content of raw additives is typically limited to total percent levels (i.e., heavy metals such as lead, $<0.0200\%$) and not the actual concentration of metal per batch. Furthermore, many of the additives imported to the US have errors in their Certificates

of Analyses.²⁷ Regardless, there are currently no routine measures of metal content per additive batch before use. Currently, fluoride additive purchases are based on AWWA and NSF Standard 60 certification, availability, and cost, but not on metal contaminant content. As of 2013, only one New Hampshire water facility had a low arsenic requirement for fluoride additives (personal communication, D. Paris, Manchester Water Treatment Plant). Utah recently passed legislation (HB 72) requiring the full disclosure of metal contaminant levels in raw fluoride additives.⁴⁷

The aim of this study was to analyze the metal content of NSF certified raw fluoride additives. Unlike previous studies of additive chemical composition, the analyses presented in this study are independent of chemical supplier data, address both liquid (HFS) and solid (NaF) forms of fluoride additives, and focus on multiple metals, not just arsenic.^{36,48} This paper also expands on safety considerations in the event of an accident, arguing that NSF's dilution approach, which focuses on one contaminant at a time, is inadequate. Such data are crucial as water facilities that fluoridate are adding potentially harmful contaminants, some carcinogenic, to drinking water.

Methods

Fluoride additives

All the fluoride additives analyzed in this study were commercially available products intended for fluoridation use at US water facilities.

Three HFS additives (HFS-1, HFS-2, and HFS-3) from different batch shipments were selected for study. Each sample was a clear liquid and consisted of 23–25% acid. The HFS additives originated from the US or Mexico (Juarez) and were labeled as AWWA/NSF certified. The origin of individual samples could not be established because manufacturer shipments were stored in common bulk tanks not cleaned between batches. The HFS samples selected for laboratory study were shipped and stored in polyethylene containers prior to analysis.

Four samples of solid fluoride additives were obtained for laboratory testing. One NaF sample (NaF-1) was in white powder form, while the remaining samples (NaF-2, NaF-3, and NaF-4) were in granular form. Each sample was taken from a different batch shipment and all samples selected for laboratory analysis were shipped and stored in individual Teflon containers. All NaF samples originated from Shanghai, China and met AWWA and NSF Standard requirements. Cross-contamination between domestic and foreign made dry additives was unlikely because US production ceased years ago. In contrast, cross-contamination between shipments of different fluoride compounds, some

intended for purposes other than fluoridation, could not be ruled out. Cross-contamination between fluoride salts originating from different countries could also not be ruled out. US suppliers repackage foreign made fluoride salts using the same equipment regardless of source and there is no wet cleaning between uses.

Analytical procedures

All fluoride additive samples required dilution in order to be within the analytical range of the testing instruments. Concentration levels of aluminum, antimony, arsenic, barium, beryllium, cadmium, calcium, chromium, copper, iron, lead, magnesium, manganese, molybdenum, nickel, potassium, selenium, silver, thallium, vanadium, and zinc were determined using EPA's Method 200.7 for inductively coupled plasma-atomic emission spectrometry (ICP).⁷ Percentage levels of fluoride and sodium were determined for all additive samples and the percentage of silicon dioxide was determined in the NaF samples and in the samples of HFS-1 and -2. The ICP determined arsenic results were confirmed by reassessment of levels using Graphite Furnace Atomic Absorption (GFAA) analysis.

Report values

Concentration values (micrograms per milliliter for liquid additives and micrograms per gram for solid additives) were expressed as parts per million (ppm) and reported when they equaled or exceeded the method detection limit (MDL) established per analyte. All concentration levels presented in the results, including those for MDL determinations, were from the raw (undiluted) fluoride additive. Each concentration value reported was an average of duplicate measures for intra-laboratory verification.

Results

Some of the results from the chemical analysis were consistent with the content expected of an AWWA and NSF certified fluoride additive. The 23–25% HFS samples contained 18–19% fluoride and sodium content of the four NaF samples met expectations (56%, NaF-1; 56.8%, NaF-2; 54.9%, NaF-3; and 57.4%, NaF-4). The sodium content of the HFS additives was 0.11% (HFS-1), 0.14% (HFS-2), and 0.05% (HFS-3). Based on two measurements, the SiO₂ content of the HFS samples ranged from 16.15% (HFS-2) to 16.55% (HFS-1). The SiO₂ content of the NaF samples was higher than expected: 24.6% in NaF-1, 26.6% in NaF-2, 26.0% in NaF-3, and 25.7% in NaF-4.

Of the 21 metal contaminants analyzed, 12 had concentration levels that were below established MDL's in the raw HFS and NaF additive samples. The contaminants with insignificant concentrations

Table 1 Contaminants with concentration levels below MDL's in raw 23–25% hydrofluorosilicic acid (HFS-1, -2, and -3) and sodium fluoride (NaF-1, -2, -3, and -4) additive samples

Analyte	MDL* (ppm)
Antimony	10.0
Beryllium	1.5
Cadmium	2.0
Chromium	10.0
Copper	10.0
Manganese	20.0
Molybdenum	10.0
Nickel	15.0
Selenium	25.0
Silver	10.0
Thallium	20.0
Vanadium	10.0

*Method detection limit

and the established MDL's per contaminant are provided in Table 1.

The remaining contaminants, including aluminum, arsenic, barium, calcium, iron, lead, magnesium, potassium, and zinc, had concentration levels that exceeded MDL's in at least one of the fluoride additive samples tested. The contaminant concentrations for the liquid HFS samples are presented in Table 2. Contaminant concentrations for the dry salt NaF additives are listed in Table 3.

Arsenic, lead, and zinc were found only in HFS additives. Arsenic in particular was present most consistently. The GFAA analysis confirmed reportable levels of arsenic in the three HFS additive samples (4.9, 34.0, and 56.0 ppm, Table 2). The HFS sample with the lowest arsenic level also contained a reportable level of lead (10.28 ppm, HFS-3, Table 2).

Barium was the only metal contaminant found exclusively in NaF additive samples (13.3 ppm, NaF-1 and 18.0 ppm, NaF-3; Table 3). Reportable levels of aluminum, calcium, iron, magnesium, and potassium were found in both the liquid and dry salt fluoride additives and concentration levels were similar in HFS and NaF samples. Concentration levels of potassium and aluminum were higher in the dry salt additives; with aluminum concentrations in the NaF samples nearly 10-fold higher than those in HFS samples. In general, aluminum was the contaminant with the highest concentration levels.

Discussion

This study demonstrates that the metal contaminant content of raw fluoride additives is highly batch-dependent. There was as much as a 10-fold difference between batches in the concentration levels of arsenic, lead, and barium, contaminants classified as a risk to human health by the National Primary

Table 2 Metal contaminant concentrations found using ICP analysis of raw 23–25% hydrofluosilicic acid additives (HFS-1, -2, and -3). Values are not corrected for density of 1.2 g/ml

Analyte	MDL* (ppm)	HFS-1 (ppm)	HFS-2 (ppm)	HFS-3 (ppm)
Aluminum	10.0	415.0	385.0	212.2
Arsenic	15.0	38.1	20.6	<15.0
	2.0 [†]	56.0 [†]	34.0 [†]	4.9 [†]
Barium	5.0	<5.0	<5.0	<5.0
Calcium	25.0	84.5	89.3	90.9
Iron	5.0	714.0	173.0	27.6
Lead	10.0	<10.0	<10.0	10.3
Magnesium	25.0	30.9	31.6	32.2
Potassium	50.0	80.0	68.0	<50.0
Zinc	10.0	27.3	<10.0	<10.0

*Method detection limit.

[†]Value determined using GFAA and a dilution of 0.1 ml/100 ml.**Table 3 Metal contaminant concentrations found using ICP analysis of raw sodium fluoride additives (NaF-1, 2, -3, and -4)**

Analyte	MDL* (ppm)	NaF-1 (ppm)	NaF-2 (ppm)	NaF-3 (ppm)	NaF-4 (ppm)
Aluminum	10.0	3393.0	3630.0	3397.0	3312.0
Arsenic	15.0	<15.0	<15.0	<15.0	<15.0
	2.0 [†]	<2.0 [†]	<2.0 [†]	<2.0 [†]	<2.0 [†]
Barium	5.0	13.3	<5.0	18.0	<5.0
Calcium	25.0	87.6	69.6	67.8	64.8
Iron	5.0	94.3	60.9	82.6	58.7
Lead	10.0	<10.0	<10.0	<10.0	<10.0
Magnesium	25.0	41.4	49.4	40.8	43.6
Potassium	50.0	192.0	221.0	346.0	171.0
Zinc	10.0	<10.0	<10.0	<10.0	<10.0

*Method detection limit.

[†]Value determined using GFAA and a dilution of 1 g/100 ml.

Drinking Water Regulations.^{49,50} As no two additive samples were found to have the same exposure profile in this study, assumptions about metal content are unreliable if based on manufacturer source or certification by NSF. Although the AWWA affirms the HFS purchasers' right to know the source of a raw product when manufactured outside North America,⁸ such information is meaningless when there is cross-contamination between HFS shipments stored in common tanks. Likewise, cross-contamination may impact metal content when all imported salt additives, regardless of source, chemical form, or intended usage are handled in the same repackaging equipment. The fact that NaF samples in this study were obtained from bulk supplies not yet repackaged, suggests that the unexpectedly high SiO₂ levels were more a function of mislabeling than cross-contamination. Contrary to label and lot number information, this analysis revealed that salt samples were likely an unidentified mix of NaF and Na₂SiF₆, two frequently used fluoride additives with different MUL's and chemical properties. Whether mislabeling or cross-contamination, the findings here indicate that users of fluoride additives can expect unpredictable amounts of metal contamination.

The only consistencies observed among the additives was that certain contaminants were always

absent (e.g., antimony, silver, and vanadium), while others were always present (e.g., aluminum, magnesium, and iron). The absent contaminants are consistent with those absent in EPA test samples of tap, pond, and well water.⁷ When compared to the content reported for other substances (Table 4), contaminant concentration levels of raw HFS additives were typically much higher than those found in tap water or in industrial or sewage treatment primary effluents.^{5-7,51} Moreover, contaminant concentration levels in raw NaF additives were much lower than those reported for contaminated solids with two notable exceptions. Barium and aluminum levels approached those that the EPA found in samples of electroplating sludge, river sediment, and hazardous soils (Table 4). The high and unpredictable contaminant levels found in the samples indicate the upper limits of possible exposures during fluoridation accidents when dilution's mitigating influence is inaccurate or altogether absent. Thus, the results here indicate that NSF's dilution approach is inappropriate. Employees who handle fluoride additives require a fail-safe strategy that takes into account the variable and hazardous metal content of the additives, both for their safety and the safety of consumers.

Arsenic has been reported as the "limiting constituent" for HFS dosage when controlling contaminants

Table 4 Measured contaminant levels in raw fluoride additives compared with measurements in environmental test samples

Analyte	Concentration levels (ppm) in raw fluoride additives*	Concentration levels (ppm) in aqueous and solid matrices reported in the literature
Arsenic HFS	4.9–56.0	0.0006 or 0.00166 average in tap water fluoridated by NSF certified HFS [†] ; <0.02 in industrial effluent [‡]
Lead HFS	<10.0–10.3	0.0006 or 0.0011 average in tap water fluoridated by NSF certified HFS [†] ; 0.251 in industrial effluent [‡] ; 0.015 in sewage treatment primary effluent [‡]
Barium NaF	<5.0–18.0	39.8 in electroplating sludge [§] ; 54.8 in river sediment [§] ; 111 in hazardous soil [§]
Aluminum HFS NaF	212.2–415.0 3312–3630	0.185 in tap water [‡] ; 1.19 in sewage treatment primary effluent [‡] 4980–5160 in electroplating sludge, hazardous soil, and river sediment [§]
Calcium HFS NaF	84.5–90.9 64.8–87.6	35.2 in tap water [‡] ; 500 in industrial effluents [‡] 28 000–85 200 in river sediment, electroplating sludge, and hazardous soil [§]
Magnesium HFS NaF	30.9–32.2 40.8–49.4	8.08 in tap water [‡] ; 6.84 in industrial effluent [‡] ; 22.7 in sewage treatment primary effluent [‡] 1950–24 400 in electroplating sludge, river sediment, and hazardous soil [§]
Iron HFS NaF	27.6–714.0 58.74–94.3	0.008 in tap water [‡] ; 1.28 in sewage treatment primary effluent [‡] 16 500–84 800 in river sediment, electroplating sludge, and hazardous soil [§]

*Data from Tables 2 and 3 of this study.

[†]Data from NSF's Tables 1 and 2.^{5,6,51}

[‡]Data from EPA's Table 6.⁷

[§]Data from EPA's Table 7.⁷

in finished drinking water.³⁶ The range of arsenic levels found in raw HFS samples was 4.9–56 ppm, similar to previous research analyzing raw HFS additives (9.4–58.5⁵² and 28–60 ppm⁴⁸). Dilution reduces the parts per million arsenic levels of raw HFS additives, to parts per billion ($\mu\text{g/l}$) arsenic levels in finished drinking water, allowing concentrations to meet established enforceable drinking water regulations. The current NSF/ANSI standard for arsenic is 0.001 ppm (1 ppb based on an MCL of 0.010 ppm).^{5,6,49,50} Table 5 provides the arsenic levels expected in finished drinking water when HFS is used for fluoridation. For example, Weng *et al.* calculated that 60 ppm arsenic in raw HFS additives would contribute 0.245 $\mu\text{g/l}$ arsenic in finished drinking water fluoridated at 1 ppm (Table 5).⁴⁸ Using this calculation, the 56.0 ppm arsenic found here in one HFS sample would become 0.224 $\mu\text{g/l}$ arsenic in finished drinking water when fluoridated at 1 ppm. As long as dilution is controlled and fluoridation stays at 1 ppm, arsenic levels (0.019–0.245 ppb in Table 5) in finished drinking water stay below the 1 ppb Standard 60 level. However, during fluoride overfeeds only the HFS additives with the lowest arsenic levels (4.9 $\mu\text{g/l}$ in Table 5) can produce drinking water where arsenic meets the Standard 60 level of 1 ppb. Moreover, fluoride non-overfeeds risk exceeding the Standard 60 level of 1 ppb arsenic when HFS additives contain high levels of arsenic (56.0–60 $\mu\text{g/l}$). The risk is even greater when there are multiple sources (e.g., natural erosion or non-fluoride water treatment chemicals) contributing arsenic to finished drinking water. Water treatment chemicals other than fluoride additives can contribute up to 0.061 μg arsenic/l of finished drinking water.⁴⁸ Combine this 0.061 $\mu\text{g/l}$ arsenic with the 0.956 or 0.873 $\mu\text{g/l}$ arsenic contributed by fluoride additives (raw additives containing 56 or 60 ppm arsenic; Table 5), and the total either exceeds the 1 ppb standard or comes close enough that there is no allowance for input from natural sources. Fluoride, but

not arsenic, is typically monitored daily when treated water enters the water delivery system. In contrast, arsenic levels are only checked quarterly or annually, depending on individual facility protocols. While HFS related non-overfeeds mean that fluoride levels are below the 4 ppm MCL/MCLG standard, it does not necessarily mean that arsenic is below the 1 ppb standard, or that arsenic is even the highest concentration contaminant of concern. The low arsenic HFS additive identified in this study (4.9 ppm arsenic) also contained 10.3 ppm lead (current NSF/ANSI standard=0.0015 ppm; MCL=0.015 ppm). The NaF additives contained neither arsenic nor lead, but did contain up to 18.0 ppm barium (current NSF/ANSI standard=0.2 ppm; MCL=2 ppm).^{5,6,49,50} Therefore, the use of arsenic as the “limiting constituent” may not be appropriate.

The arsenic, lead, and barium content of raw fluoride additives pit health risks against technological feasibility and drinking water regulations. For these contaminants, standards are based on health concerns, technology, and cost.^{49,50} Technological allowances are for geogenic sources that contribute substantially to source water contamination. In short, standards are relaxed to allow for arsenic, lead, and barium to be introduced into drinking water via erosion of natural deposits.^{49,50} When present in fluoride additives, these contaminants are added to natural sources of contaminants, complicating control over site-specific erosion problems and in turn the estimation of total contaminant exposure. Without such allowances, the standards would be solely health-based and provide margins of safety adequate to protect against adverse health effects. Such health-based standards are the EPA’s Maximum Contaminant Level Goals (MCLG’s), which are set at 0 ppm for arsenic and lead, and 2 ppm for barium.^{49,50} The 0 ppm MCLG for arsenic was established because arsenic exposure is associated with skin and cardiovascular damage, lung cancer,

Table 5 Raw HFS additive arsenic content converted to concentration levels expected in finished drinking water with fluoridation at desired (1 ppm), non-overfeed (3.9 ppm), and overfeed (24–200 ppm) dilutions

Raw HFS additives – analytical results for arsenic (ppm)	Finished drinking water – calculated estimate* of arsenic concentrations ($\mu\text{g/l}$) during desired, non-overfeed, and overfeed fluoride situations		
	Desired F-level 1.0 ppm	Non-overfeed F-level 3.9 ppm [‡]	Overfeed F-level 24 ppm [§]
56.0 [†]	0.224	0.873	5.38
34.0 [†]	0.136	0.530	3.26
4.9 [†]	0.019	0.076	0.470
60	0.245	0.956	5.88
28	0.114	0.446	2.75

*Calculation method of Weng *et al.*⁴⁸

[†]HFS solution designated as 24.0%.

[‡]Fluoride non-overfeed range=1.2–4.0 mg/l.

[§]Reported accidental fluoride overfeed level.¹³

^{||}Reported HFS analytical result for arsenic⁴⁸ (24.5% HFS solution).

[†]Reported finished drinking water arsenic level.⁴⁸

and bladder cancer. Similarly, the 0 ppm MCLG was established for lead because lead exposure can cause physical and mental developmental delays, attention and learning deficit disorders, kidney damage and hypertension. The 2 ppm MCLG for barium was created because of its hypertensive effects. The MCLG of zero indicates that any amount of lead or arsenic in drinking water, whether derived from natural or artificial sources, poses a risk to human health.

While it is known that arsenic in HFS increases the numbers of lung and bladder cancers in the United States,⁵³ no consideration has been given to the arsenic and lead levels in HFS overfeeds and non-overfeeds. Non-overfeeds are a particularly insidious exposure since they are unreported for months and total contaminant contribution is ignored. As water operators continue to focus only on desired fluoride levels (1 ppm), health consequences will be systematically underestimated and potential carcinogens may enter into the public water system.

The high levels of aluminum in raw fluoride additives raise questions about the adequacy of current drinking water regulations. Along with calcium, iron, and magnesium, aluminum is regulated under the National Secondary Drinking Water Regulations as a technical and an esthetic nuisance, not as a risk to human health.^{49,50} Some nuisance contaminants are considered essential and possibly protective against cardiovascular and cerebrovascular mortality.^{54,55} In drinking water, aluminum and iron can cause undesirable color, tastes, and/or odors, but neither has an enforceable MCL for health-based concerns. Federal regulations do not require state health agencies and public water systems to monitor aluminum levels in water supplies, and aluminum levels are not determined when an NSF certified fluoride additive is dosed into water at a MUL.^{5,6,49,50} Aluminum is not a limiting constituent for any water treatment chemical and is only restricted when an aluminum-based flocculant is used to remove naturally occurring excess fluoride and/or unwanted color and turbidity from water supplies.^{36,56,57} After this removal process, residual aluminum levels should not exceed 0.2 ppm. This concentration is low enough that drinking water contributes a much smaller proportion of the lifetime burden of aluminum than food.^{49,50,58,59} However, this flocculation limit does not relate to the later process of fluoridation, which is the last step in water treatment before drinking water is delivered. It is assumed that NaF additives contain only small amounts of aluminum.⁶⁰ This is not a safe assumption given the 212–415 ppm aluminum found in the HFS samples and the near electroplating sludge levels (3312–3630 ppm) found in the NaF samples (Table 4). Findings from this study indicate that

fluoride additives deliver a larger proportion of the daily aluminum intake than previously realized, and unknown concentrations of aluminum fluoride complexes are reaching consumers via fluoridation.

Concerns that aluminum in drinking water threatens health are countered by claims of low toxic potential due to poor gastrointestinal (GI) absorption.⁶¹ The level of aluminohydroxide complexes in city water supplies ($21.8 \pm 10 \mu\text{g/l}^{58}$) seems trivial compared to the 400 mg of aluminum hydroxide found in one over-the-counter antacid tablet. However, this comparison is misleading. Although only a small portion of the antacid aluminum gets absorbed, it is enough to accumulate and cause premature osteoporosis, encephalopathy, and proximal myopathy during renal insufficiency.⁶² Manufacturers of antacids counterbalance aluminum with magnesium hydroxide in order to cancel the adverse effects the two metals have on the bowel.⁶² Furthermore, patients are warned not to take antacids concomitantly with certain medications because aluminum hinders essential drug absorption by forming Al-drug insoluble complexes.⁶² This exceptional binding strength is why aluminum is no longer used as a phosphate binder to treat renal osteodystrophy. It promotes adynamic bone disease (low bone turnover), anemia, myopathy, and dementia.⁶³ In short, aluminum exposure via antacids is not comparable to exposure from drinking water. Antacids contain aluminum in the hydroxide form. Aluminum in food additives is usually in the form of a sulfate, silicate, or phosphate,⁶⁴ and human absorption of aluminum sulfates and silicates is largely unknown, while that of relatively insoluble aluminum phosphates depends upon the amounts consumed.⁶⁵ Gastrointestinal absorption of aluminum varies by quantity and chemical form.^{66,67} Drinking water contains multiple forms of aluminum, including aluminum-fluoride complexes, which are readily absorbed in the GI tract and cross the blood-brain barrier.^{32,68,69} It is the aluminum-fluoride complex form that has the greatest potential for biological impact, where toxicity stems from mimicking gamma-phosphate, altering enzyme activity and activating guanine nucleotide-binding proteins (G-proteins), which are integral to endocrine and nervous system functions.^{60,70–78} Al-fluoride complexes have been shown to be markedly more toxic than fluoride alone regarding deposition of aluminum in the brain and kidney and cerebrovascular and neuronal integrity.³² The much greater biological impact of the Al-fluoride complex, or fluoride coexisting with aluminum or beryllium, constitutes a threat to human health no longer dismissible on the basis of poor GI absorption.

Contaminant interactions should be considered in determining drinking water regulations. The finding of high aluminum levels in raw fluoride samples

underscores the inadequacy of regulations based on SPAC limits. There is no justification for the disparate limits, 0.2 ppm for aluminum and 1.2 ppm for fluoride, especially when the greatest toxic concern is the Al-fluoride complex. To build in a margin of safety, other contaminants have limits that are one-tenth their MCL. In contrast, the 1.2 ppm fluoride limit is less than one-third its MCL, providing no margin of safety to cover the potential toxicity of Al-fluoride complexes. While prior studies have investigated the potential link between Alzheimer's disease and aluminum in drinking water at levels as low as 0.1–0.2 ppm,^{79–82} it may be more important to investigate the association between Alzheimer's and levels of Al-fluoride complexes.

While many variables influence Al-fluoride complex formation, control over the formation starts with the disclosure of aluminum content in raw fluoride additives. When aluminum is only regulated as a water quality nuisance, only fluoride is considered for its potential health effects. Too narrow a focus on fluoride artificially limits populations at risk to those with compromised fluoride excretion (renal insufficiency), excluding those with higher than normal aluminum absorption (e.g., the elderly, Alzheimer and Down's syndrome patients^{83,84}). This shortsighted exclusion is avoidable if drinking water regulations addressed exposures to Al-fluoride complexes in addition to individual aluminum or fluoride levels.

In summary, raw fluoride additives contain significant levels of arsenic, lead, barium, and aluminum not addressed by current regulations with health-based standards. These raw product levels establish the upper limits of exposure in the event of fluoride overfeeds, non-overfeeds, and industrial accidents. Although the findings of this study are limited by small numbers of samples and manufacturing sources, they highlight flaws in the quality control of NSF certification. Controlled dilution procedures needed to meet NSF/ANSI standards camouflage the fact that metal contaminants are being removed from water sources only to be returned to finished water supplies via fluoridation. The use of fluoride additives assures that some risk is passed to the consumer, especially with regard to arsenic, lead, and non-overfeed levels of fluoride (1.2–4 ppm) that can persist undisclosed up to a year. Since January 2011, there has been a proposed recommendation to lower the optimum fluoridation level to 0.7 ppm. This proposal remains without regulatory standing and has been ignored. Considering this study's findings, the following recommendations outline controls needed to fill the gaps in current regulations:

1. All metal contaminants with concentrations that reach or exceed MDL's of analytical instrumentation should be identified per batch shipment,

regardless of source, before being used as a treatment chemical in public water supplies. Records of actual contaminant concentrations should be kept and made available to the public on request and to first responders during accidental spills.

2. Fluoridation levels should not exceed 0.4 ppm (one-tenth the fluoride MCL) in order to provide a margin of safety for interacting contaminants. Fluoridation above 0.4 ppm should not be attempted unless the aluminum and beryllium in raw additives are at levels below MDL's.
3. Raw additives with low arsenic, lead, and barium levels should be used when source waters contain these contaminants in naturally high concentrations. If such additives are unobtainable, the use of fluoride additives should be discontinued.
4. In conjunction with the use of fluoride additives, aluminum should have an established MCL and be regulated under the National Primary Drinking Water Regulations.

There must be a concerted effort to improve transparency with respect to the contaminant content of raw fluoride additives. Adopting the above recommendations would be a major step in alleviating the growing concerns for safety.

Disclaimer statements

Contributors No contributors/guarantor to declare.

Funding Supported in part by the Fluoride Toxicity Research Collaborative of Second Look.

Conflicts of interest The author has no conflicts-of-interest to declare.

Ethics approval Not applicable.

Acknowledgments

The author thanks the Town of Selmer, Tennessee for providing one of the fluoride additives that was analyzed in this study.

References

- 1 Mortvedt JJ. Heavy metal contaminants in inorganic and organic fertilizers. *Fertil Res.* 1996;43:55–61.
- 2 Mortvedt JJ, Beaton JD. Heavy metal and radionuclide contaminants in phosphate fertilizers. In: Tiessen H, editor. *Phosphorus in the global environment*. New York: John Wiley and Sons Ltd.; 1995. p. 93–106.
- 3 Dissanayake CB, Chandrajith R. Phosphate mineral fertilizers, trace metals and human health. *J Natl Sci Found Sri Lanka.* 2009;37:153–65.
- 4 Mortvedt JJ, Giordano PM. Crop uptake of heavy-metal contaminants in fertilizers. In: Drucker H, Wildung RE, editors. *Biological implications of heavy metals in the environment*. Conf.-750929, Tennessee: ERDA; 1977. p. 402–16.
- 5 National Sanitation Foundation International. NSF Fact Sheet on Fluoridation Chemicals. Available from: www.nsf.org/business/water_distribution/pdf/NSF_Fact_Sheet.pdf (accessed 2012 June).
- 6 National Sanitation Foundation International. NSF Fact Sheet on Fluoridation Chemicals. Available from: www.nsf.org/newsroom_pdf/NSF_Fact_Sheet_on_Fluoridation.pdf (accessed 2013 February).
- 7 US Environmental Protection Agency. Determination of metals and trace elements in water and wastes by inductively coupled plasma-atomic emission spectrometry. Revision 4.4 EMMC

- Version, Cincinnati, OH: Environmental Monitoring Systems Laboratory, Office of Research and Development; 1994.
- 8 American Water Works Association. AWWA standard for fluorosilicic acid, ANSI/AWWA B703-11; 2011.
 - 9 Reeves TG. Water Fluoridation. A Manual for Engineers and Technicians. Atlanta, US Department of Health & Human Services, Public Health Service, CDC, 1986.
 - 10 American Water Works Association. Fluoride overfeed can have serious consequences. *Opflow*; 1993;19:5.
 - 11 Carton R. Middletown Maryland latest city to receive toxic spill of fluoride in their drinking water. *Townsend Letter for Doctors*, October, 1994.
 - 12 Washington R. Norfolk could teach Wakefield about posting water alerts. *Boston Herald*, 9 August 2000.
 - 13 Foskett SH. Marlboro water flooded with fluoride. *Worcester Telegram and Gazette*, 25 October 2003.
 - 14 Detroit Now-WXYZ-TV. Spilled acid concerns residents in Macomb County, 29 July 2002.
 - 15 Russell K. Fluoride suspected as 23 in Dublin grow ill. *Contra Costa Times*, 5 June 2002.
 - 16 The Oregonian. Partially treated sewage enters Coos Bay waters. 3 October 2000.
 - 17 Hardin J. Water plant loses fluoride. *Post and Courier*, 4 August 2000.
 - 18 Griner D. Spill call delayed 2 hours. *The Journal Gazette*, 22 February 2001.
 - 19 Donovan P. Update: three people treated for injuries following chemical leak. St. Louis, MO: KSDK; 2009.
 - 20 Rizzo R. Hazmat teams rush to fluoride spill in Parleys Creek. *The Salt Lake Tribune*, 31 August 2007.
 - 21 WQAD News. Hazmat crews respond to chemical spill at Rock Island water treatment plant. 24 March 2011.
 - 22 National Response Center. Incident Summary Reports 723353; 709565; 632081; 627070; 594739; 590129; 571290; 562139; 552909; 549345; 537343 and 525003. Available from: www.nrc.uscg.mil/pls/apex/f?p=109:1:2000-2004.
 - 23 Gessner BD, Beller M, Middaugh JP, Whitford GM. Acute fluoride poisoning from a public water system. *N Engl J Med*. 1994;330:95-9.
 - 24 Petersen LR, Denis D, Brown D, Hadler JL, Helgerson SD. Community health effects of a municipal water supply hyperfluoridation accident. *Am J Public Health*. 1988;78:711-3.
 - 25 Sidhu KS, Kimmer RO. Fluoride overfeed at a well site near an elementary school in Michigan. *J Environ Health*. 2002;65:16-21.
 - 26 Penman AD, Brackin BT, Embrey R. Outbreak of acute fluoride poisoning caused by a fluoride overfeed, Mississippi, 1993. *Public Health Rep*. 1997;112:403-9.
 - 27 Waterwatch of Utah. Elective water additive. H₂SiF₆-Na₂SiF₆-NaF. Risks and Liabilities. Homeland Security and Source Water Protection. Case Study, Fluoride Spill Mt. Dell Reservoir-Parley's Canyon. 31 August 2007.
 - 28 Doull J. Factors influencing toxicology. In: Casarett LJ, Doull J, editors. *Toxicology. The basic science of poisons*. New York: Macmillan Publishing Co.; 1975. p. 133-47.
 - 29 Agency for Toxic Substances and Disease Registry (ATSDR). Interaction profile for arsenic, cadmium, chromium and lead. Atlanta, GA: U. S. Department of Health and Human Services, Public Health Service; 2004.
 - 30 Stokinger HE, Ashenburg NJ, DeVoldre J, Scott JK, Smith FA. The enhancing effect of the inhalation of hydrogen fluoride vapor on beryllium sulfate poisoning in animals. University of Rochester Atomic Energy Project, Contract W-7401-eng-49, 4 April 1949.
 - 31 Eisenbud M. (Brush Beryllium Company-Luckey Experience). Memorandum to W. B. Harris regarding acute beryllium toxicity. 27 February 1961. (Germantown DOE History Archive.)
 - 32 Varner JA, Jensen KF, Horvath W, Isaacson RL. Chronic administration of aluminum-fluoride or sodium-fluoride to rats in drinking water: alterations in neuronal and cerebrovascular integrity. *Brain Res*. 1998;784:284-98.
 - 33 Sternweis PC, Gilman AG. Aluminum: a requirement for activation of the regulatory component of adenylate cyclase by fluoride. *Proc Natl Acad Sci USA*. 1982;79:4888-91.
 - 34 Kirk KL. Biochemistry of inorganic fluoride. In: *Biochemistry of the elemental halogens and inorganic halides*. New York: Plenum Press; 1991. p. 19-68.
 - 35 Isaacson RL, Varner JA, Jensen KF. Toxin-induced blood vessel inclusions caused by the chronic administration of aluminum and sodium fluoride and their implications for dementia. *Neuroprotective Agents. Ann N Y Acad Sci*. 1997;825:152-66.
 - 36 Brown RA, Cornwell DA, MacPhee MJ. Trace contaminants in water treatment chemicals: sources and fate. *J AWWA*. 2004;96:111-25.
 - 37 American Conference of Governmental Industrial Hygienists. Hydrogen fluoride. Cincinnati, OH: ACGIH; 2005.
 - 38 Kharasch ED. Sevoflurane: the challenges of safe formulation. *APSF Newsl*. 2007;48:55.
 - 39 O'Neill B, Hafiz MA, DeBeer DA. Corrosion of Penlon sevoflurane vaporizers. *Anesthesia*. 2007;62:421.
 - 40 Saltarelli M. Abbott addresses sevoflurane formulation. *APSF Newsl*. 2007;21:86.
 - 41 Kharasch ED, Subbarao GN, Cromack KR, Stephens DA, Saltarelli MD. Sevoflurane formulation water content influences degradation by Lewis Acids in vaporizers. *Anesth Analg*. 2009;108:1796-802.
 - 42 Raloff J. Drugged waters. Does it matter that pharmaceuticals are turning up in water supplies? *Sci News*. 1998;153:187-9.
 - 43 Fick, J, Soderstrom H, Lindberg RH, Phan C, Tyskland M, Larsson DGJ. Contamination of surface, ground, and drinking water from pharmaceutical production. *Environ Toxicol Chem*. 2009;28:2522-7.
 - 44 Hodge HC, Smith FA. Biological properties of inorganic fluorides. In: Simons JH, editor. *Fluorine chemistry*. New York: Academic Press; 1965. p. 41.
 - 45 Gosselin RE, Hodge HC, Smith RP, Gleason MN. *Ingredients index*. In: *Clinical toxicology of commercial products. Acute poisoning*, 4th edn. Baltimore: Williams and Wilkins Co; 1976. p. 78.
 - 46 Simonin P, Pierron A. Toxicite brute des derives fluores. *C R Seances Soc Biol Ses Fil*. 1937;124:133-4.
 - 47 Utah State Legislature. Utah House Bill HB 72: Safe Drinking Water Disclosure Act. Available from: <http://openstates.org/ut/bills/2013/HB72/documents/UTD00025488/>; 2013
 - 48 Weng C-N, Smith DB, Huntley GM. Treatment chemicals contribute to arsenic levels. *Opflow*. 2000;10:6-7.
 - 49 US Environmental Protection Agency. Water: drinking water contaminants. Available from: water.epa.gov/drink/contaminants/index.cfm. EPA 816-F-09-0004 (accessed 2009 May).
 - 50 US Environmental Protection Agency. 2012 Edition of the Drinking Water Standards and Health Advisories. Washington, DC: US Environmental Protection Agency, Office of Water, EPA 822-S-12-001, 2012. Available from: <http://water.epa.gov/drink/standards/hascience.cfm> <http://water.epa.gov/action/advisories/drinking/upload/dwstandards2012.pdf>
 - 51 Hazan S (NSF International, Drinking Water Additives Certification Program). Letter to Ken Calvert, Chairman Subcommittee on Energy and the Environment, Committee on Science, US House of Representatives, 7 July 2000.
 - 52 Casale R. Improving chemical handling procedures can help reduce associated treatment problems. *J AWWA*. 2001;93:95-106.
 - 53 Hirzy JW, Carton RJ, Bonanni CD, Montanero CM, Nagle MF. Comparison of hydrofluorosilicic acid and pharmaceutical sodium fluoride as fluoridating agents-A cost-benefit analysis. *Environ Sci Policy*. 2013;29:81-6. [In Press Corrigendum. *Environ Sci Policy*. 2013, Available form: <http://dx.doi.org/10.1016/j.envsci.2013.11.002>].
 - 54 Ferrandiz J, Abellan JJ, Gomez-Rubio V, Lopez-Quilez A, Sanmartin P, Abellan C, *et al*. Spatial analysis of the relationship between mortality from cardiovascular and cerebrovascular disease and drinking water hardness. *Environ Health Perspect*. 2004;112:1037-44.
 - 55 Rubenowitz E, Molin I, Axelsson G, Rylander R. Magnesium in drinking water in relation to morbidity and mortality from acute myocardial infarction. *Epidemiology*. 2000;11:416-21.
 - 56 Bratby J. *Coagulation and flocculation in water and wastewater treatment*, 2nd edn. London: IWA Publishing; 2006.
 - 57 Jekel MR, Heinzmann B. Residual aluminum in drinking-water treatment. *JWSRT Aqua*. 1989;38:281-8.
 - 58 Driscoll CT, Letterman RD. Chemistry and fate of Al(III) in treated drinking water. *J Environ Eng*. 1988;114:21-37.
 - 59 Rogers MAM, Simon DG. A preliminary study of dietary aluminium intake and risk of Alzheimer's disease. *Age Ageing*. 1999;28:205-9.
 - 60 Li L. The biochemistry and physiology of metallic fluoride: action, mechanism, and implications. *Crit Rev Oral Biol Med*. 2003;14:100-14.
 - 61 Hunter Water. Fact Sheet. Drinking water: alum in water treatment. Available from: www.hunterwater.com.au/Resources/

- Documents/Fact-Sheets/Water-Quality/ALUM-IN-DRINKING-WATER_MAR2011.pdf
- 62 Hoogerwerf WA, Pasricha PJ. Pharmacotherapy of gastric acidity, peptic ulcers, and gastroesophageal reflux disease. In: Brunton LL, Lazo JS, Parker KL, editors. Goodman & Gilman's the pharmacological basis of therapeutics, 11th edn. New York: McGraw-Hill Medical Publishing Division; 2006. p. 967–81.
 - 63 Friedman PA. Agents affecting mineral ion homeostasis and bone turnover. In: Brunton LL, Lazo JS, Parker KL, editors. Goodman & Gilman's the pharmacological basis of therapeutics, 11th edn. New York: McGraw-Hill Medical Publishing Division; 2006. p. 1647–78.
 - 64 Pennington JA. Aluminium content of foods and diets. *Food Addit Contam.* 1987;5:161–232.
 - 65 Kaehny WD, Hegg AP, Alfrey AC. Gastrointestinal absorption of aluminium from aluminium-containing antacids. *New Engl J Med.* 1977;296:1389–90.
 - 66 Slanina P, Frech W, Ekstrom LG, Loof L, Slorach S, Cedergren A. Dietary citric acid enhances absorption of aluminium in antacids. *Clin Chem.* 1986;32:539–41.
 - 67 Harris WR, Berthon G, Day JP, Exley C, Flaten TP, Forbes WF, *et al.* Speciation of aluminum in biological systems. *J Toxicol Environ Health.* 1996;48:543–68.
 - 68 Varner JA, Horvath WJ, Huie CW, Naslund HR, Isaacson RL. Chronic aluminum fluoride administration: I. Behavioral observations. *Behav Neural Biol.* 1994;61:233–41.
 - 69 Varner JA, Huie CW, Horvath WJ, Jensen KF, Isaacson RL. Chronic AlF₃ administration: II. Selected histological observations. *Neurosci Res Commun.* 1993;13:99–104.
 - 70 Bigay J, Deterre P, Pfister C, Chabre M. Fluoroaluminates activate transducin-GDP by mimicking the gamma-phosphate of GTP in its binding site. *FEBS Lett.* 1985;191:181–5.
 - 71 Bigay J, Deterre P, Pfister C, Chabre M. Fluoride complexes of aluminium or beryllium act on G-proteins as reversibly bound analogues of the gamma phosphate of GTP. *EMBO J.* 1987;6:2907–13.
 - 72 Chabre M. Aluminofluoride and berylliofluoride complexes: new phosphate analogs in enzymology. *Trends Biochem Sci.* 1990;15:6–10.
 - 73 Li L, Fleming N. Aluminum fluoride inhibits phospholipase D activation by a GTP-binding protein-independent mechanism. *FEBS Lett.* 1999;458:419–23.
 - 74 Parker KL, Schimmer BP. Pituitary hormones and their hypothalamic releasing factors. In: Brunton LL, Lazo JS, Parker KL, editors. Goodman & Gilman's the pharmacological basis of therapeutics, 11th edn. New York: McGraw-Hill Medical Publishing Division; 2006. p. 1489–510.
 - 75 Farwell AP, Braverman LE. Thyroid and antithyroid drugs. In: Brunton LL, Lazo JS, Parker KL, editors. Goodman & Gilman's the pharmacological basis of therapeutics, 11th edn. New York: McGraw-Hill Medical Publishing Division; 2006. p. 1511–40.
 - 76 Schimmer BP, Parker KL. Adrenocorticotrophic hormone; adrenocortical steroids and their synthetic analogs; inhibitors of the synthesis and actions of adrenocortical hormones. In: Brunton LL, Lazo JS, Parker KL, editors. Goodman & Gilman's the pharmacological basis of therapeutics, 11th edn. New York: McGraw-Hill Medical Publishing Division; 2006. p. 1587–612.
 - 77 Westfall TC, Westfall DP. Neurotransmission. The autonomic and somatic motor nervous systems. In: Brunton LL, Lazo JS, Parker KL, editors. Goodman & Gilman's the pharmacological basis of therapeutics, 11th edn. New York: McGraw-Hill Medical Publishing Division; 2006. p. 137–81.
 - 78 Strunecka A, Strunecky O, Patočka J. Fluoride plus aluminum: useful tools in laboratory investigations, but messengers of false information. *Physiol Res.* 2002;51:557–64.
 - 79 Neri LC, Hewitt D. Aluminium, Alzheimer's disease, and drinking water. *Lancet.* 1991;338:390.
 - 80 Forbes WF, McAiney CA. Aluminium and dementia. *Lancet.* 1992;340:668–9.
 - 81 Jacquemin H, Commenges D, Letenneur L, Barberger-Gateau P, Dartigues JF. Components of drinking water and risk of cognitive impairment in the elderly. *Am J Epidemiol.* 1994;139:48–57.
 - 82 McLachlan DRC, Bergeron C, Smith JE, Boomer D, Rifat SL. Risk for neuropathologically confirmed Alzheimer's disease and residual aluminium in municipal drinking water employing weighted residential histories. *Neurology.* 1996;46:401–5.
 - 83 Taylor GA, Ferrier IN, McLoughlin IJ, Fairbairn AF, McKeith IG, Lett D, *et al.* Gastrointestinal absorption of aluminium in Alzheimer's disease: response to aluminium citrate. *Age Ageing.* 1992;21:81–90.
 - 84 Moore PB, Edwardson JA, Ferrier IN, Taylor GA, Lett D, Tyrer SP, *et al.* Gastrointestinal absorption of aluminium is increased in Down's syndrome. *Biol Psychiatry.* 1997;41:488–92.